

## Annual Drinking Water Quality Report for 2022

Wooded Acres Mobile Home Park

307 Rathburn Road

Public Water Supply ID # NY3700940

### INTRODUCTION

To comply with State and Federal regulations, Wooded Acres Mobile Home Park will be issuing an annual report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water awareness and the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Brian Dooley, the owner and water operator at (315) 924-1934. We want you to be informed about your drinking water, and we will be available to discuss any drinking water issues in person.

### WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the New York State Department of Health (NYS DOH) and the Environmental Protection Agency (EPA) prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The NYS DOH and the Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### FACTS AND FIGURES:

Our water system currently serves approximately 40 people through 14 service connections. The park's water source consists of one 45-foot drilled well. The well is located within the mobile home park by the pump house. The well water is pumped to one 3,000-gallon storage tank. The water is disinfected with liquid sodium hypochlorite (chlorine) by an injection pump at the pump house prior to distribution.

### **SOURCE WATER ASSESSMENT:**

The NYS DOH has completed a source water assessment for this system. Possible and actual threats to this drinking water source were evaluated by reviewing limited existing mapped data and available information from past sanitary surveys. The state source water assessment provides a susceptibility rating based on the potential risk posed by each possible source of contamination and how easily contaminants could move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessment was completed to provide owners and operators with additional information to help them protect your source waters into the future.

As mentioned before, our water is derived from a single drilled well. The source water assessment has rated this well as having a very high susceptibility to nitrates, bacteria & viruses, high susceptibility to salts, sulfate, industrial solvents, petroleum products, metals and other industrial contaminants. It has a medium-high susceptibility rating for herbicide/pesticide contamination. These ratings are due primarily to the proximity of a permitted discharge facility (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) and the presence of nearby septic systems. In addition, the well is believed to draw from a fractured bedrock aquifer and no lower permeability layer exists above it. This means that the overlying soils may not provide adequate protection from potential contamination.

Please note that the finished water delivered into your home meets the New York State's drinking water standards.

County and State Health Departments will use this risk assessment information to direct future source water protection activities. These may include water quality monitoring, wellhead protection, resource management, planning, and education programs. A copy of the assessment can be obtained by contacting us, as noted below.

### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, halo acetic acids, radiological and synthetic organic compounds. In 2021, Wooded Acres MHP began sampling for the newly emerging chemical contaminants; 1,4 Dioxane, PFOA & PFOS. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Oswego County Health Department at (315) 349-3564.

## Table Of Detected Compounds

Contaminant	Violation (Yes/No)	Date of Sample	Level Detected	Unit Measurement	MCLG	MCL, TT, or AL	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Barium	No	10/03/22	0.511	mg/L	2mg/L	2mg/L	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Copper <sup>^1</sup>	No	08/26/14	0.036	mg/L	1.3 mg/L	AL = 1.3 mg/L	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
Nitrate (As Nitrogen)	No	02/23/22	1.3	mg/L	10 mg/L	10mg/L	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Sodium <sup>^2</sup>	No	5/9/2006	28	mg/L	N/A	N/A	Naturally occurring; road salt; water softeners; Animal waste.

### Radioactive Contaminates

Radium 226	No	2/28/2022	0.273	pCi/L	0pCi/L	5pCi/L <sup>^3</sup>	Erosion of natural deposits
Radium 228	No	2/28/2022	1.84	pCi/L	0pCi/L	5pCi/L <sup>^3</sup>	Erosion of natural deposits
Gross Alpha	No	2/28/2022	1.13	pCi/L	0pCi/L	15pCi/L <sup>^4</sup>	Erosion of natural deposits

#### Notes:

- 1: Average of 2 samples.
- 2: Water containing more than 20 mg/L of sodium should not be used for drinking by persons on severely restricted sodium diets. Water containing more than 270 mg/L of sodium should not be used for drinking by people on moderately restricted sodium diets.
- 3: MCL is for combined Radium 226 & 228.
- 4: Gross alpha excludes Radon & Uranium.

#### DEFINITIONS:

**Action Level** – The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** – The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** – The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Parts per million (ppm) or Milligrams per liter (mg/L)** – Corresponds to one part of liquid in one million parts of liquid (parts per million – ppm). Or one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/L)** – Corresponds to one part of liquid in one billion parts of liquid (parts per billion – ppb). Or one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** – A measure of radioactivity in water.

### **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

^

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wooded Acres MHP is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from lead in your home plumbing. You can take responsibility by indentifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Brian Dooley at 315-924-1934. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

^

### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2022, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

### **DO I NEED TO TAKE PRECAUTIONS? IS OUR WATER SAFE FOR EVERYONE?**

Although our drinking water met or exceeded State and Federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia, and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791). Please note that testing of the water at this system has shown that this water is suitable for drinking water purposes, and contains very low amounts of contaminants and should not pose any health risks.

### **INFORMATION FOR NON-ENGLISH-SPEAKING RESIDENTS**

Spanish:

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo

entienda bien.

French:

Ce rapport contient des informations importantes sur votre eau potable. Traduisez le ou parlez en avec quelqu'un qui le comprend bien.

#### **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

#### **CLOSING**

Thank you for allowing us to continue providing your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary to address improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please review the attached water source protection, and water conservation tips sheet. Please call our office if you have questions.



## Water Conservation Tips For Oswego County Residents

### *REPAIR ALL LEAKS*

A dripping faucet is more than annoying...it is expensive. Even small leaks can waste significant amounts of water...Hot water leaks are a waste of water and of the energy used to heat the water.

Leaks inside the toilet can waste up to 200 gallons a day. Toilet leaks can be detected by adding a few drops of food coloring to water in the toilet tank. If the colored water appears in the bowl, the toilet is leaking.

If you have a leaking faucet or toilet, stop pouring money down the drain and repair it.

### *HOW TO SAVE WATER IN THE BATHROOM*

The bathroom consumes 75% of our water usage. Controlling this flow is the key to big water and energy saving.

- When constructing a new home or remodeling your bathroom, install low consumption (1.6 gal/flush) toilets. Older toilets use 3.5 to 6 gallons per flush.
- Place a weighted plastic gallon jug in the tanks of conventional toilets to displace and save an equal amount of water with each flush.
- Install low-flow aerators and shower heads. They are inexpensive, easy to install, and save water and energy.
- Do not let the faucet flow while brushing your teeth or shaving. Use a glass of water for rinsing teeth.
- Take showers instead of tub baths. Consider bathing small children together.
- If your shower has a single-handle control or shut-off valve, turn off the flow while soaping or shampooing.
- Leaking diverter valves (valves which divert water from the tub spout to the shower head) should be replaced.

### *HOW TO SAVE WATER IN THE KITCHEN AND LAUNDRY*

- Refrigerate a bottle of drinking water instead of letting a faucet flow until the water is cold enough to drink.
- Use a dishpan or plug the sink for washing and rinsing dishes. Install a low-flow aerator on all faucets.
- Pre-rinsing dishes prior to loading in a dishwasher only when they are fully loaded.
- Operate the washing machine and dishwasher only when they are fully loaded.
- Use the proper water level or load size selection on the washing machine
- When purchasing a washing machine or dishwasher, consider water consumption as well as energy efficiency. Most manufacturers now provide this information to consumers.

### *HOW TO SAVE WATER OUTSIDE THE HOME*

The watering of lawns and gardens can double normal household water use during the hot, dry summer months. At standard household water pressures, a garden hose will discharge up to 6.5 gallons of water per minute. To apply an inch of water to 1,000 square feet of lawn or garden requires 620 gallons of water.

Watering should be limited to gardens and newly planted lawns and landscaped areas. Established lawns and landscape plantings will usually survive without watering. Inadequate watering encourages shallow root growth and increases the risk of mortality. When water is scarce, your community or individual water supply should be reserved for your most essential needs.

## ***HOW TO SAVE WATER OUTSIDE THE HOME (CON'T)***

The following water-saving measures should be practiced regularly, but remember, during mandatory water use restrictions, all water use outside the home is prohibited!

- Use a broom, not a hose, to clean driveways, steps, and sidewalks.
- Wash the car with water from a bucket.
- If a hose must be used, control the flow with an automatic shut-off nozzle.
- Water the lawn or garden during the coolest part of the day. Do not water on windy days.
- Set sprinklers to water the lawn or garden only. Do not water the street or sidewalk.
- Use soaker hoses and trickle irrigation systems to reduce the amount of water used for irrigation by 20 to 50 percent.
- Use mulch around shrubs and garden plants to reduce evaporation from the soil surface and cut down on weed growth.
- Use native plants in landscaping your lawn, because they require less care and water than ornamental varieties.

## ***HOW TO CONSERVE WATER IN THE COMMUNITY***

Encourage the use of water conservation devices by large water-using facilities such as schools, health clubs, motels and others.

- Survey water users within large water using facilities and develop plans to reduce water use.
- Encourage a community-based service organization such as a scout group, service club, or church youth group to start a water conservation program . Water conservation is a stewardship of our natural resources.
- Encourage use of drought tolerant vegetation in outdoor landscaping at large facilities and community sites.
- Retrofit older buildings and facilities with water-efficient plumbing fixtures.

**Oswego County Health Department  
70 Bunner Street  
Oswego, New York 13126  
315-349-3557 or 1-800-286-2906**